ANALYSIS REPORT



Tigard, OR 97223

С

Tel.: (503) 639-9311 Fax: (503) 684-1588

Reported: 02/16/2022 Received: 02/01/2022 Sampled By: Charles Spear Work Order: 2033060

Project:

Project #: -

Sample Type: Grab

PO #: 2021096

Sampling Location: Bridges Career & Technical School

Environmental Inspection Services

L Attn: Charles Spear
E 11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Lab Number							
	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2033060-01	Sample Name: 2053 08 Sampled: 1/29/22 16:00		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	ND	ppb	1	15 ppb	02/14/22 16:06
2033060-02	Sample Name: 2053 08 Sampled: 1/29/22 16:03		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	6	ppb	1	15 ppb	02/14/22 16:06
2033060-03	Sample Name: 2053 08 Sampled: 1/29/22 16:05		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	2	ppb	1	15 ppb	02/14/22 16:06
2033060-04	Sample Name: 2053 08 Sampled: 1/29/22 16:06		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	2	ppb	1	15 ppb	02/14/22 16:06
2033060-05	Sample Name: 2053 08 Sampled: 1/29/22 16:10		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	2	ppb	1	15 ppb	02/14/22 16:06
2033060-06	Sample Name: 2053 08 Sampled: 1/29/22 16:10		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	4	ppb	1	15 ppb	02/14/22 16:06
2033060-07	Sample Name: 2053 08 Sampled: 1/29/22 16:11		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	4	ppb	1	15 ppb	02/14/22 16:06
2033060-08	Sample Name: 2053 08 Sampled: 1/29/22 16:12		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	8	ppb	1	15 ppb	02/14/22 16:06
2033060-09	Sample Name: 2053 08 Sampled: 1/29/22 16:13		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	2	ppb	1	15 ppb	02/14/22 16:06
2033060-10	Sample Name: 2053 08 Sampled: 1/29/22 16:15		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	1	ppb	1	15 ppb	02/14/22 16:06

ANALYSIS REPORT



Tigard, OR 97223

С

Т

Tel.: (503) 639-9311 Fax: (503) 684-1588

Reported: 02/16/2022 Received: 02/01/2022 Sampled By: Charles Spear Work Order: 2033060

Project:

Project #: -

Sample Type: Grab

PO #: 2021096

Sampling Location: Bridges Career & Technical School

Environmental Inspection Services

L Attn: Charles Spear ı 11981 Fargo Rd Ε Aurora OR, 97002 Ν Phone: (503) 680-6398

Lab Number							
	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2033060-11	Sample Name: 2053 00 Sampled: 1/29/22 16:20		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	3	ppb	1	15 ppb	02/14/22 16:06
2033060-12	Sample Name: 2053 06 Sampled: 1/29/22 16:21		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	ND	ppb	1	15 ppb	02/14/22 16:06
2033060-13	Sample Name: 2053 06 Sampled: 1/29/22 16:23		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	8	ppb	1	15 ppb	02/14/22 16:06
2033060-14	Sample Name: 2053 08 Sampled: 1/29/22 16:24		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	3	ppb	1	15 ppb	02/14/22 16:06
2033060-15	Sample Name: 2053 08 Sampled: 1/29/22 16:25		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	2	ppb	1	15 ppb	02/14/22 16:06
2033060-16	Sample Name: 2053 08 Sampled: 1/29/22 16:26		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	1	ppb	1	15 ppb	02/14/22 16:06
2033060-17	Sample Name: 2053 06 Sampled: 1/29/22 16:27		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	1	ppb	1	15 ppb	02/14/22 16:06
2033060-18	Sample Name: 2053 06 Sampled: 1/29/22 16:28		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	2	ppb	1	15 ppb	02/14/22 16:06
2033060-19	Sample Name: 2053 08 Sampled: 1/29/22 16:29		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	6	ppb	1	15 ppb	02/14/22 16:06
2033060-20	Sample Name: 2053 08 Sampled: 1/29/22 16:30		omposition: Rav	v Single			Matrix: Drinking Water
† <i>Lead</i>	1030	EPA 200.9	2	ppb	1	15 ppb	02/14/22 16:06



Tigard, OR 97223

С

L

Τ

Ε

Ν

Т

Tel.: (503) 639-9311 Fax: (503) 684-1588

Reported: 02/16/2022 Received: 02/01/2022 Sampled By: Charles Spear Work Order: 2033060

Project:

Project #: -

Sample Type: Grab

PO #: 2021096

Sampling Location: Bridges Career & Technical School

Environmental Inspection Services

Attn: Charles Spear 11981 Fargo Rd Aurora OR, 97002 Phone: (503) 680-6398

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2033060-21	Sample Name: 2053 08	300 BF 360 22A					Matrix: Drinking Water
	Sampled: 1/29/22 16:32	Sample Co	mposition: Rav	v Single			
† <i>Lead</i>	1030	EPA 200.9	7	ppb	1	15 ppb	02/14/22 16:06
2033060-22	Sample Name: 2053 08	300 BF 361 22A					Matrix: Drinking Water
	Sampled: 1/29/22 16:32	Sample Co	mposition: Rav	v Single			
† <i>Lead</i>	1030	EPA 200.9	ND	ppb	1	15 ppb	02/14/22 16:06
2033060-23	Sample Name: 2053 08	300 CF 362 22A					Matrix: Drinking Water
	Sampled: 1/29/22 16:33	Sample Co	mposition: Rav	v Single			
† <i>Lead</i>	1030	EPA 200.9	2	ppb	1	15 ppb	02/14/22 16:06
2033060-24	Sample Name: 2053 08	300 CF 363 22A					Matrix: Drinking Water
	Sampled: 1/29/22 16:34	Sample Co	mposition: Rav	v Single			
† <i>Lead</i>	1030	EPA 200.9	2	ppb	1	15 ppb	02/14/22 16:06
2033060-25	Sample Name: 2053 08	300 CF 364 22A					Matrix: Drinking Water
	Sampled: 1/29/22 16:35	Sample Co	mposition: Rav	v Single			
† <i>Lead</i>	1030	EPA 200.9	8	ppb	1	15 ppb	02/14/22 16:06

ND = None detected at the MRL

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by:

Adriana Gonzalez-Gray Laboratory Director

MRL = Minimum Reporting Limit

MCL = Maximum Contamination Limit

[†]All procedures for this analysis are in accordance with NELAP standards.

^{*} The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.