



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/16/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2033009

**C  
L  
I  
E  
N  
T**  
**Environmental Inspection Services**  
Attn: Charles Spear  
11981 Fargo Rd  
Aurora OR, 97002  
Phone: (503) 680-6398

**Project:** JCMS  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: Jefferson County Middle School

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2033009-01</b>	<b>Sample Name:</b> 5053 0600 250 SF 22A <b>Sampled:</b> 1/29/22 12:20 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	3	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-02</b>	<b>Sample Name:</b> 5053 0600 251 BF 22A <b>Sampled:</b> 1/29/22 12:21 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-03</b>	<b>Sample Name:</b> 5053 0600 252 BF 22A <b>Sampled:</b> 1/29/22 12:22 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-04</b>	<b>Sample Name:</b> 5053 0600 253 BF 22A <b>Sampled:</b> 1/29/22 12:25 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-05</b>	<b>Sample Name:</b> 5053 0600 254 BF 22A <b>Sampled:</b> 1/29/22 12:27 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-06</b>	<b>Sample Name:</b> 5053 0600 255 BF 22A <b>Sampled:</b> 1/29/22 12:30 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-07</b>	<b>Sample Name:</b> 5053 0600 256 WB 22A <b>Sampled:</b> 1/29/22 12:32 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-08</b>	<b>Sample Name:</b> 5053 0600 257 CF 22A <b>Sampled:</b> 1/29/22 12:34 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-09</b>	<b>Sample Name:</b> 5053 0600 258 CF 22A <b>Sampled:</b> 1/29/22 12:34 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-10</b>	<b>Sample Name:</b> 5053 0600 259 CF 22A <b>Sampled:</b> 1/29/22 12:35 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/10/22 15:56



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/16/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2033009

**C  
L  
I  
E  
N  
T**  
**Environmental Inspection Services**  
Attn: Charles Spear  
11981 Fargo Rd  
Aurora OR, 97002  
Phone: (503) 680-6398

**Project:** JCMS  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: Jefferson County Middle School

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2033009-11</b>	<b>Sample Name:</b> 5053 0600 260 CF 22A <b>Sampled:</b> 1/29/22 12:40 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	8	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-12</b>	<b>Sample Name:</b> 5053 0600 261 CF 22A <b>Sampled:</b> 1/29/22 12:40 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-13</b>	<b>Sample Name:</b> 5053 0600 262 CF 22A <b>Sampled:</b> 1/29/22 12:40 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-14</b>	<b>Sample Name:</b> 5053 0600 263 CF 22A <b>Sampled:</b> 1/29/22 12:40 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-15</b>	<b>Sample Name:</b> 5053 0600 264 CF 22A <b>Sampled:</b> 1/29/22 12:41 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-16</b>	<b>Sample Name:</b> 5053 0600 265 CF 22A <b>Sampled:</b> 1/29/22 12:41 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-17</b>	<b>Sample Name:</b> 5053 0600 266 CF 22A <b>Sampled:</b> 1/29/22 12:41 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-18</b>	<b>Sample Name:</b> 5053 0600 267 BF 22A <b>Sampled:</b> 1/29/22 12:42 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-19</b>	<b>Sample Name:</b> 5053 0600 268 BF 22A <b>Sampled:</b> 1/29/22 12:42 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-20</b>	<b>Sample Name:</b> 5053 0600 269 BF 22A <b>Sampled:</b> 1/29/22 12:42 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/16/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2033009

**C  
L  
I  
E  
N  
T**  
**Environmental Inspection Services**  
Attn: Charles Spear  
11981 Fargo Rd  
Aurora OR, 97002  
Phone: (503) 680-6398

**Project:** JCMS  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: Jefferson County Middle School

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2033009-21</b>	<b>Sample Name:</b> 5053 0600 270 KF 22A <b>Sampled:</b> 1/29/22 12:43 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-22</b>	<b>Sample Name:</b> 5053 0600 271 KF 22A <b>Sampled:</b> 1/29/22 12:43 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-23</b>	<b>Sample Name:</b> 5053 0600 272 KF 22A <b>Sampled:</b> 1/29/22 12:44 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-24</b>	<b>Sample Name:</b> 5053 0600 273 KF 22A <b>Sampled:</b> 1/29/22 12:44 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-25</b>	<b>Sample Name:</b> 5053 0600 274 KF 22A <b>Sampled:</b> 1/29/22 12:44 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-26</b>	<b>Sample Name:</b> 5053 0600 275 KF 22A <b>Sampled:</b> 1/29/22 12:45 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-27</b>	<b>Sample Name:</b> 5053 0600 276 CF 22A <b>Sampled:</b> 1/29/22 12:45 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-28</b>	<b>Sample Name:</b> 5053 0600 CF 277 22A <b>Sampled:</b> 1/29/22 12:46 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-29</b>	<b>Sample Name:</b> 5053 0600 BF 278 22A <b>Sampled:</b> 1/29/22 12:46 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-30</b>	<b>Sample Name:</b> 5053 0600 BF 279 22A <b>Sampled:</b> 1/29/22 12:46 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/16/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2033009

**C  
L  
I  
E  
N  
T**  
**Environmental Inspection Services**  
Attn: Charles Spear  
11981 Fargo Rd  
Aurora OR, 97002  
Phone: (503) 680-6398

**Project:** JCMS  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: Jefferson County Middle School

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2033009-31</b>	<b>Sample Name:</b> 5053 0600 280 CF 22A <b>Sampled:</b> 1/29/22 12:48 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-32</b>	<b>Sample Name:</b> 5053 0600 281 BF 22A <b>Sampled:</b> 1/29/22 12:48 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-33</b>	<b>Sample Name:</b> 5053 0600 282 BF 22A <b>Sampled:</b> 1/29/22 12:48 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-34</b>	<b>Sample Name:</b> 5053 0600 283 BF 22A <b>Sampled:</b> 1/29/22 12:49 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-35</b>	<b>Sample Name:</b> 5053 0600 284 BF 22A <b>Sampled:</b> 1/29/22 12:49 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-36</b>	<b>Sample Name:</b> 5053 0600 285 CF 22A <b>Sampled:</b> 1/29/22 12:50 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-37</b>	<b>Sample Name:</b> 5053 0600 286 CF 22A <b>Sampled:</b> 1/29/22 12:50 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-38</b>	<b>Sample Name:</b> 5053 0600 287 CF 22A <b>Sampled:</b> 1/29/22 12:51 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	4	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-39</b>	<b>Sample Name:</b> 5053 0600 288 CF 22A <b>Sampled:</b> 1/29/22 12:51 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	5	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-40</b>	<b>Sample Name:</b> 5053 0600 289 CF 22A <b>Sampled:</b> 1/29/22 12:51 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/16/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2033009

**C** Environmental Inspection Services  
**L** Attn: Charles Spear  
**I** 11981 Fargo Rd  
**E** Aurora OR, 97002  
**N** Phone: (503) 680-6398  
**T**

**Project:** JCMS  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: Jefferson County Middle School

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2033009-41</b>	<b>Sample Name:</b> 5053 0600 290 CF 22A <b>Sampled:</b> 1/29/22 12:52 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-42</b>	<b>Sample Name:</b> 5053 0600 291 CF 22A <b>Sampled:</b> 1/29/22 12:52 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	3	ppb	1	15 ppb	02/14/22 16:06
<b>2033009-43</b>	<b>Sample Name:</b> 5053 0600 292 CF 22A <b>Sampled:</b> 1/29/22 12:52 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-44</b>	<b>Sample Name:</b> 5053 0600 293 CF 22A <b>Sampled:</b> 1/29/22 12:53 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-45</b>	<b>Sample Name:</b> 5053 0600 294 CF 22A <b>Sampled:</b> 1/29/22 12:53 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-46</b>	<b>Sample Name:</b> 5053 0600 295 CF 22A <b>Sampled:</b> 1/29/22 12:53 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-47</b>	<b>Sample Name:</b> 5053 0600 296 BF 22A <b>Sampled:</b> 1/29/22 12:54 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-48</b>	<b>Sample Name:</b> 5053 0600 297 BF 22A <b>Sampled:</b> 1/29/22 12:54 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-49</b>	<b>Sample Name:</b> 5053 0600 298 BF 22A <b>Sampled:</b> 1/29/22 12:54 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-50</b>	<b>Sample Name:</b> 5053 0600 299 BF 22A <b>Sampled:</b> 1/29/22 12:54 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/16/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2033009

**C  
L  
I  
E  
N  
T**  
**Environmental Inspection Services**  
Attn: Charles Spear  
11981 Fargo Rd  
Aurora OR, 97002  
Phone: (503) 680-6398

**Project:** JCMS  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: Jefferson County Middle School

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2033009-51</b>	<b>Sample Name:</b> 5053 0600 300 BF 22A <b>Sampled:</b> 1/29/22 12:55 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-52</b>	<b>Sample Name:</b> 5053 0600 301 BF 22A <b>Sampled:</b> 1/29/22 12:55 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-53</b>	<b>Sample Name:</b> 5053 0600 302 WB 22A <b>Sampled:</b> 1/29/22 12:55 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-54</b>	<b>Sample Name:</b> 5053 0600 303 BF 22A <b>Sampled:</b> 1/29/22 12:56 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-55</b>	<b>Sample Name:</b> 5053 0600 304 BF 22A <b>Sampled:</b> 1/29/22 12:56 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-56</b>	<b>Sample Name:</b> 5053 0600 305 SF 22A <b>Sampled:</b> 1/29/22 12:56 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-57</b>	<b>Sample Name:</b> 5053 0600 306 BF 22A <b>Sampled:</b> 1/29/22 12:57 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-58</b>	<b>Sample Name:</b> 5053 0600 307 BF 22A <b>Sampled:</b> 1/29/22 12:57 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-59</b>	<b>Sample Name:</b> 5053 0600 308 SF 22A <b>Sampled:</b> 1/29/22 12:57 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	14	ppb	1	15 ppb	02/10/22 15:56
<b>2033009-60</b>	<b>Sample Name:</b> 5053 0600 309 BF 22A <b>Sampled:</b> 1/29/22 12:58 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/14/22 16:06



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/16/2022
Received: 02/01/2022
Sampled By: Charles Spear
Work Order: 2033009

C Environmental Inspection Services

Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: JCMS

Project #: -
Sample Type: Grab
PO #: 2021096

Sampling Location: Jefferson County Middle School

Lab Number

Table with 8 columns: Code, Method, Result, Units, MRL, EPA MCL\*, Analysis Date/ Time. Row 1: 2033009-61, Sample Name: 5053 0600 310 BF 22A, Matrix: Drinking Water. Row 2: †Lead, 1030, EPA 200.9, 3, ppb, 1, 15 ppb, 02/14/22 16:06.

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by:

Handwritten signature of Adriana Gonzalez-Gray

Adriana Gonzalez-Gray
Laboratory Director