



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/14/2022
Received: 02/01/2022
Sampled By: Charles Spear
Work Order: 2033004

C Environmental Inspection Services
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Madras H/S
Project # : -
Sample Type : Grab
PO # : 2021096

Sampling Location: Madras High School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2033004-01	Sample Name: 20530500 SF 120 22A						Matrix: Drinking Water
	Sampled: 1/28/22 13:35						
	Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2033004-02	Sample Name: 20530500 SF 121 22A						Matrix: Drinking Water
	Sampled: 1/28/22 13:35						
	Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2033004-03	Sample Name: 20530500 BF 122 22A						Matrix: Drinking Water
	Sampled: 1/28/22 13:36						
	Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2033004-04	Sample Name: 20530500 SF 123 22A						Matrix: Drinking Water
	Sampled: 1/28/22 13:36						
	Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2033004-05	Sample Name: 20530500 BF 124 22A						Matrix: Drinking Water
	Sampled: 1/28/22 13:38						
	Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2033004-06	Sample Name: 20530500 SF 125 22A						Matrix: Drinking Water
	Sampled: 1/28/22 13:38						
	Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/08/22 15:24
2033004-07	Sample Name: 20530500 BF 126 22A						Matrix: Drinking Water
	Sampled: 1/28/22 13:38						
	Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/08/22 15:24
2033004-08	Sample Name: 20530500 WB 127 22A						Matrix: Drinking Water
	Sampled: 1/28/22 13:39						
	Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2033004-09	Sample Name: 20530500 BF 128 22A						Matrix: Drinking Water
	Sampled: 1/28/22 13:39						
	Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/08/22 15:24
2033004-10	Sample Name: 20530500 BF 129 22A						Matrix: Drinking Water
	Sampled: 1/28/22 13:40						
	Sample Composition: Raw Single						
+Lead	1030	EPA 200.9	4	ppb	1	15 ppb	02/08/22 15:24



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/14/2022
Received: 02/01/2022
Sampled By: Charles Spear
Work Order: 2033004

C Environmental Inspection Services
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Madras H/S
Project # : -
Sample Type : Grab
PO # : 2021096

Sampling Location: Madras High School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2033004-11	Sample Name: 20530500 CF 130 22A Sampled: 1/28/22 13:45 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	5	ppb	1	15 ppb	02/08/22 15:24
2033004-12	Sample Name: 20530500 CF 131 22A Sampled: 1/28/22 13:46 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/08/22 15:24
2033004-13	Sample Name: 20530500 CF 132 22A Sampled: 1/28/22 13:53 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	3	ppb	1	15 ppb	02/09/22 15:47
2033004-14	Sample Name: 20530500 CF 133 22A Sampled: 1/28/22 13:55 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-15	Sample Name: 20530500 CF 134 22A Sampled: 1/28/22 13:55 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-16	Sample Name: 20530500 DW 135 22A Sampled: 1/28/22 13:56 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-17	Sample Name: 20530500 (BOT) 136 22A Sampled: 1/28/22 13:57 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-18	Sample Name: 20530500 CF 137 22A Sampled: 1/28/22 13:58 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	8	ppb	1	15 ppb	02/09/22 15:47
2033004-19	Sample Name: 20530500 CF 138 22A Sampled: 1/28/22 13:59 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-20	Sample Name: 20530500 CF 139 22A Sampled: 1/28/22 14:00 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/14/2022
Received: 02/01/2022
Sampled By: Charles Spear
Work Order: 2033004

C Environmental Inspection Services
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Madras H/S
Project # : -
Sample Type : Grab
PO # : 2021096

Sampling Location: Madras High School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2033004-21	Sample Name: 20530500 WB 140 22A						Matrix: Drinking Water
	Sampled: 1/28/22 14:00		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-22	Sample Name: 20530500 WB 141 22A						Matrix: Drinking Water
	Sampled: 1/28/22 14:05		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-23	Sample Name: 20530500 BF 142 22A						Matrix: Drinking Water
	Sampled: 1/28/22 14:10		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-24	Sample Name: 20530500 DW 143 22A						Matrix: Drinking Water
	Sampled: 1/28/22 14:15		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-25	Sample Name: 20530500 CF 144 22A						Matrix: Drinking Water
	Sampled: 1/28/22 14:16		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-26	Sample Name: 20530500 CF 145 22A						Matrix: Drinking Water
	Sampled: 1/28/22 14:23		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-27	Sample Name: 20530500 CF 146 22A						Matrix: Drinking Water
	Sampled: 1/28/22 14:23		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	7	ppb	1	15 ppb	02/09/22 15:47
2033004-28	Sample Name: 20530500 CF 147 22A						Matrix: Drinking Water
	Sampled: 1/28/22 14:24		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-29	Sample Name: 20530500 DW 148 22A						Matrix: Drinking Water
	Sampled: 1/28/22 14:24		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-30	Sample Name: 20530500 WB 149 22A						Matrix: Drinking Water
	Sampled: 1/28/22 14:25		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/09/22 15:47



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/14/2022
Received: 02/01/2022
Sampled By: Charles Spear
Work Order: 2033004

C Environmental Inspection Services

L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Madras H/S

Project # : -

Sample Type : Grab

PO # : 2021096

Sampling Location: Madras High School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2033004-31	Sample Name: 20530500 BF 150 22A Sampled: 1/28/22 14:25 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/09/22 15:47
2033004-32	Sample Name: 20530500 BF 151 22A Sampled: 1/28/22 14:27 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/09/22 15:47
2033004-33	Sample Name: 20530500 BF 152 22A Sampled: 1/28/22 14:28 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/09/22 15:47
2033004-34	Sample Name: 20530500 SF 153 22A Sampled: 1/28/22 14:29 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-35	Sample Name: 20530500 SF 154 22A Sampled: 1/28/22 14:29 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/09/22 15:47
2033004-36	Sample Name: 20530500 SF 155 22A Sampled: 1/28/22 14:30 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/09/22 15:47
2033004-37	Sample Name: 20530500 BF 156 22A Sampled: 1/28/22 14:31 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/09/22 15:47
2033004-38	Sample Name: 20530500 BF 157 22A Sampled: 1/28/22 14:32 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/09/22 15:47
2033004-39	Sample Name: 20530500 BF 158 22A Sampled: 1/28/22 14:33 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-40	Sample Name: 20530500 BF 159 22A Sampled: 1/28/22 14:33 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/14/2022
Received: 02/01/2022
Sampled By: Charles Spear
Work Order: 2033004

C Environmental Inspection Services
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Madras H/S
Project # : -
Sample Type : Grab
PO # : 2021096

Sampling Location: Madras High School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2033004-41	Sample Name: 20530500 CF 160 22A Sampled: 1/28/22 14:34 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-42	Sample Name: 20530500 BF 161 22A Sampled: 1/28/22 14:35 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	3	ppb	1	15 ppb	02/09/22 15:47
2033004-43	Sample Name: 20530500 BF 162 22A Sampled: 1/28/22 14:35 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/09/22 15:47
2033004-44	Sample Name: 20530500 CF 163 22A Sampled: 1/28/22 14:36 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-45	Sample Name: 20530500 BF 164 22A Sampled: 1/28/22 14:36 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	4	ppb	1	15 ppb	02/09/22 15:47
2033004-46	Sample Name: 20530500 BF 165 22A Sampled: 1/28/22 14:37 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-47	Sample Name: 20530500 CF 166 22A Sampled: 1/28/22 14:37 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	4	ppb	1	15 ppb	02/09/22 15:47
2033004-48	Sample Name: 20530500 CF 167 22A Sampled: 1/28/22 14:38 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-49	Sample Name: 20530500 CF 168 22A Sampled: 1/28/22 14:39 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-50	Sample Name: 20530500 CF 169 22A Sampled: 1/28/22 14:40 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/14/2022
Received: 02/01/2022
Sampled By: Charles Spear
Work Order: 2033004

C Environmental Inspection Services
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Madras H/S
Project # : -
Sample Type : Grab
PO # : 2021096

Sampling Location: Madras High School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2033004-51	Sample Name: 20530500 CF 170 22A Sampled: 1/28/22 14:45 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-52	Sample Name: 20530500 CF 171 22A Sampled: 1/28/22 14:46 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-53	Sample Name: 20530500 BF 172 22A Sampled: 1/28/22 14:47 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	4	ppb	1	15 ppb	02/09/22 15:47
2033004-54	Sample Name: 20530500 BF 173 22A Sampled: 1/28/22 14:48 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	11	ppb	1	15 ppb	02/09/22 15:47
2033004-55	Sample Name: 20530500 BF 174 22A Sampled: 1/28/22 14:49 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/09/22 15:47
2033004-56	Sample Name: 20530500 BF 175 22A Sampled: 1/28/22 14:50 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/09/22 15:47
2033004-57	Sample Name: 20530500 BF 176 22A Sampled: 1/28/22 14:55 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/09/22 15:47
2033004-58	Sample Name: 20530500 BF 177 22A Sampled: 1/28/22 15:00 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-59	Sample Name: 20530500 BF 178 22A Sampled: 1/28/22 15:00 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-60	Sample Name: 20530500 BF 179 22A Womens RO Sampled: 1/28/22 15:00 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	11	ppb	1	15 ppb	02/09/22 15:47



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/14/2022
Received: 02/01/2022
Sampled By: Charles Spear
Work Order: 2033004

C Environmental Inspection Services
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Madras H/S
Project # : -
Sample Type : Grab
PO # : 2021096

Sampling Location: Madras High School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2033004-61	Sample Name: 20530500 BF 180 22A Sampled: 1/28/22 15:05 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	10	ppb	1	15 ppb	02/09/22 15:47
2033004-62	Sample Name: 20530500 BF 181 22A Sampled: 1/28/22 15:06 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	5	ppb	1	15 ppb	02/09/22 15:47
2033004-63	Sample Name: 20530500 BF 182 22A Sampled: 1/28/22 15:07 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/09/22 15:47
2033004-64	Sample Name: 20530500 BF 183 22A Sampled: 1/28/22 15:10 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-65	Sample Name: 20530500 BF 184 22A Sampled: 1/28/22 15:11 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-66	Sample Name: 20530500 DW 185 22A Sampled: 1/28/22 15:12 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-67	Sample Name: 20530500 BOT 186 22A Sampled: 1/28/22 15:12 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-68	Sample Name: 20530500 DW 187 22A Sampled: 1/28/22 15:16 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-69	Sample Name: 20530500 BF 188 22A Sampled: 1/28/22 15:17 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/09/22 15:47
2033004-70	Sample Name: 20530500 CF 189 22A Sampled: 1/28/22 15:18 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/14/2022
Received: 02/01/2022
Sampled By: Charles Spear
Work Order: 2033004

C Environmental Inspection Services
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: Madras H/S
Project # : -
Sample Type : Grab
PO # : 2021096

Sampling Location: Madras High School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2033004-71	Sample Name: 20530500 DW 190 22A Sampled: 1/28/22 15:20 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/09/22 15:47
2033004-72	Sample Name: 20530500 DW 191 22A Sampled: 1/28/22 15:21 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/09/22 15:47
2033004-73	Sample Name: 20530500 DW 192 22A Sampled: 1/28/22 15:22 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-74	Sample Name: 20530500 DW 193 22A Sampled: 1/28/22 15:23 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-75	Sample Name: 20530500 DW 194 22A Sampled: 1/28/22 15:25 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-76	Sample Name: 20530500 DW 195 22A Sampled: 1/28/22 15:26 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-77	Sample Name: 20530500 BF 196 22A Sampled: 1/28/22 15:27 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-78	Sample Name: 20530500 BF 197 22A Sampled: 1/28/22 15:28 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
2033004-79	Sample Name: 20530500 BF 198 22A Sampled: 1/28/22 15:29 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	3	ppb	1	15 ppb	02/09/22 15:47
2033004-80	Sample Name: 20530500 DW 195 22A Sampled: 1/28/22 15:30 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/14/2022
Received: 02/01/2022
Sampled By: Charles Spear
Work Order: 2033004

C Environmental Inspection Services

Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: Madras H/S

Project #: -
Sample Type: Grab
PO #: 2021096

Sampling Location: Madras High School

Lab Number

Table with 8 columns: Code, Method, Result, Units, MRL, EPA MCL*, Analysis Date/ Time. Row 1: 2033004-81, Sample Name: 20530500 DW 200 22A, Matrix: Drinking Water. Row 2: †Lead, 1030, EPA 200.9, ND, ppb, 1, 15 ppb, 02/09/22 15:47.

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by:

Handwritten signature of Adriana Gonzalez-Gray

Adriana Gonzalez-Gray
Laboratory Director