



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/14/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2033007

**C  
L  
I  
E  
N  
T** Environmental Inspection Services

Attn: Charles Spear  
11981 Fargo Rd  
Aurora OR, 97002  
Phone: (503) 680-6398

**Project:** ME  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: Madras Elementary

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2033007-01</b>	<b>Sample Name:</b> 20530300 201 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 7:45 <b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
<b>2033007-02</b>	<b>Sample Name:</b> 20530300 202 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 7:45 <b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/09/22 15:47
<b>2033007-03</b>	<b>Sample Name:</b> 20530300 203 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 7:50 <b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/09/22 15:47
<b>2033007-04</b>	<b>Sample Name:</b> 20530300 204 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 7:50 <b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/09/22 15:47
<b>2033007-05</b>	<b>Sample Name:</b> 20530300 205 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 7:53 <b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	4	ppb	1	15 ppb	02/09/22 15:47
<b>2033007-06</b>	<b>Sample Name:</b> 20530300 206 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 7:55 <b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	34	ppb	4	15 ppb	02/09/22 15:47 <b>MCLE</b>
<b>2033007-07</b>	<b>Sample Name:</b> 20530300 207 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 7:57 <b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	4	ppb	1	15 ppb	02/09/22 15:47
<b>2033007-08</b>	<b>Sample Name:</b> 20530300 208 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 7:58 <b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/09/22 15:47
<b>2033007-09</b>	<b>Sample Name:</b> 20530300 209 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 8:00 <b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	3	ppb	1	15 ppb	02/09/22 15:47
<b>2033007-10</b>	<b>Sample Name:</b> 20530300 210 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 8:02 <b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/09/22 15:47



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/14/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2033007

**C  
L  
I  
E  
N  
T**  
**Environmental Inspection Services**  
Attn: Charles Spear  
11981 Fargo Rd  
Aurora OR, 97002  
Phone: (503) 680-6398

**Project:** ME  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: Madras Elementary

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2033007-11</b>	<b>Sample Name:</b> 20530200 211 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 8:05		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	9	ppb	1	15 ppb	02/09/22 15:47
<b>2033007-12</b>	<b>Sample Name:</b> 20530200 212 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 8:07		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	4	ppb	1	15 ppb	02/09/22 15:47
<b>2033007-13</b>	<b>Sample Name:</b> 20530200 213 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 8:12		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	3	ppb	1	15 ppb	02/09/22 15:47
<b>2033007-14</b>	<b>Sample Name:</b> 20530200 214 CF 22A class 4						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 8:45		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	4	ppb	1	15 ppb	02/09/22 15:47
<b>2033007-15</b>	<b>Sample Name:</b> 20530200 215 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 9:00		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
<b>2033007-16</b>	<b>Sample Name:</b> 20530200 216 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 9:03		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	3	ppb	1	15 ppb	02/09/22 15:47
<b>2033007-17</b>	<b>Sample Name:</b> 20530200 217 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 9:05		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/09/22 15:47
<b>2033007-18</b>	<b>Sample Name:</b> 20530200 218 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 9:05		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-19</b>	<b>Sample Name:</b> 20530200 219 DW 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 9:10		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-20</b>	<b>Sample Name:</b> 20530200 220 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 9:15		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/14/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2033007

**C** Environmental Inspection Services  
**L** Attn: Charles Spear  
**I** 11981 Fargo Rd  
**E** Aurora OR, 97002  
**N** Phone: (503) 680-6398  
**T**

**Project:** ME  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: Madras Elementary

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2033007-21</b>	<b>Sample Name:</b> 20530200 221 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 9:20						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	4	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-22</b>	<b>Sample Name:</b> 20530200 222 KF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 9:20						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	4	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-23</b>	<b>Sample Name:</b> 20530200 223 KF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 9:20						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-24</b>	<b>Sample Name:</b> 20530200 224 KF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 9:30						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-25</b>	<b>Sample Name:</b> 20530200 225 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 9:35						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-26</b>	<b>Sample Name:</b> 20530200 226 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 9:40						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-27</b>	<b>Sample Name:</b> 20530200 227 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 9:50						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-28</b>	<b>Sample Name:</b> 20530200 228 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 9:56						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-29</b>	<b>Sample Name:</b> 20530200 229 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 9:58						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-30</b>	<b>Sample Name:</b> 20530200 230 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 10:00						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/10/22 15:56



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/14/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2033007

**C** Environmental Inspection Services  
**L** Attn: Charles Spear  
**I** 11981 Fargo Rd  
**E** Aurora OR, 97002  
**N** Phone: (503) 680-6398  
**T**

**Project:** ME  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: Madras Elementary

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2033007-31</b>	<b>Sample Name:</b> 20530200 231 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 10:30						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-32</b>	<b>Sample Name:</b> 20530200 232 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 10:31						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-33</b>	<b>Sample Name:</b> 20530200 233 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 10:35						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-34</b>	<b>Sample Name:</b> 20530200 234 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 10:40						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-35</b>	<b>Sample Name:</b> 20530200 235 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 10:43						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	9	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-36</b>	<b>Sample Name:</b> 20530200 236 CF 22A Rm 21						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 10:45						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-37</b>	<b>Sample Name:</b> 20530200 237 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 10:50						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-38</b>	<b>Sample Name:</b> 20530200 238 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 10:52						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-39</b>	<b>Sample Name:</b> 20530200 239 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 10:55						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-40</b>	<b>Sample Name:</b> 20530200 240 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 11:00						
	<b>Sample Composition:</b> Raw Single						
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/10/22 15:56



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/14/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2033007

**C  
L  
I  
E  
N  
T** **Environmental Inspection Services**

Attn: Charles Spear  
11981 Fargo Rd  
Aurora OR, 97002  
Phone: (503) 680-6398

**Project:** ME  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: Madras Elementary

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2033007-41</b>	<b>Sample Name:</b> 20530200 BF 241 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 11:40		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-42</b>	<b>Sample Name:</b> 20530200 CF 242 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 11:41		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-43</b>	<b>Sample Name:</b> 20530200 CF 243 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 11:42		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/10/22 15:56
<b>2033007-44</b>	<b>Sample Name:</b> 20530200 CF 244 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/29/22 11:45		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/10/22 15:56

**MCLE** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

**Note:** Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: \_\_\_\_\_

Adriana Gonzalez-Gray  
Laboratory Director