



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/14/2022
Received: 02/01/2022
Sampled By: Charles Spear
Work Order: 2032022

C Environmental Inspection Services
L Attn: Charles Spear
I 11981 Fargo Rd
E Aurora OR, 97002
N Phone: (503) 680-6398
T

Project: District Office
Project # : -
Sample Type : Grab
PO # : 2021098

Sampling Location: 445 SE Buff. Madras

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2032022-01	Sample Name: 2053000 DW 034 22A						Matrix: Drinking Water
	Sampled: 1/28/22 9:15		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2032022-02	Sample Name: 2053000 BF 035 22A						Matrix: Drinking Water
	Sampled: 1/28/22 9:15		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2032022-03	Sample Name: 2053000 BF 036 22A						Matrix: Drinking Water
	Sampled: 1/28/22 9:15		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2032022-04	Sample Name: 2053000 SF 037 22A						Matrix: Drinking Water
	Sampled: 1/28/22 9:20		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2032022-05	Sample Name: 2053000 SF 038 22A						Matrix: Drinking Water
	Sampled: 1/28/22 9:25		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/08/22 15:24
2032022-06	Sample Name: 2053000 SF 039 22A						Matrix: Drinking Water
	Sampled: 1/28/22 9:25		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24
2032022-07	Sample Name: 2053000 BF 040 22A						Matrix: Drinking Water
	Sampled: 1/28/22 9:30		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/08/22 15:24
2032022-08	Sample Name: 2053000 BF 041 22A						Matrix: Drinking Water
	Sampled: 1/28/22 9:30		Sample Composition: Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/08/22 15:24

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/14/2022
Received: 02/01/2022
Sampled By: Charles Spear
Work Order: 2032022

C
L
I
E
N
T
Environmental Inspection Services
Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: District Office
Project # : -
Sample Type : Grab
PO # : 2021098

Sampling Location: 445 SE Buff. Madras

Lab Number

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director