



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/18/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2034034

**C  
L  
I  
E  
N  
T** **Environmental Inspection Services**

Attn: Charles Spear  
11981 Fargo Rd  
Aurora OR, 97002  
Phone: (503) 680-6398

**Project:** WSA

Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: Warm Springs Academy 50 Chukar Rd. Warm Springs, OR 977

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2034034-01</b>	<b>Sample Name:</b> 2053 0400 500 SF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 10:30		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/14/22 16:06
<b>2034034-02</b>	<b>Sample Name:</b> 2053 0400 501 SF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 10:31		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/14/22 16:06
<b>2034034-03</b>	<b>Sample Name:</b> 2053 0400 502 SF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 10:31		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/14/22 16:06
<b>2034034-04</b>	<b>Sample Name:</b> 2053 0400 503 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 10:32		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/14/22 16:06
<b>2034034-05</b>	<b>Sample Name:</b> 2053 0400 504 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 10:32		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-06</b>	<b>Sample Name:</b> 2053 0400 505 SF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 10:32		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-07</b>	<b>Sample Name:</b> 2053 0400 506 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 10:33		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-08</b>	<b>Sample Name:</b> 2053 0400 507 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 10:34		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-09</b>	<b>Sample Name:</b> 2053 0400 508 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 10:34		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-10</b>	<b>Sample Name:</b> 2053 0400 509 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 10:35		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/16/22 14:10



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/18/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2034034

**C** Environmental Inspection Services  
**L** Attn: Charles Spear  
**I** 11981 Fargo Rd  
**E** Aurora OR, 97002  
**N** Phone: (503) 680-6398  
**T**

**Project:** WSA  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: Warm Springs Academy 50 Chukar Rd. Warm Springs, OR 977

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2034034-11</b>	<b>Sample Name:</b> 2053 0400 510 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 10:50		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-12</b>	<b>Sample Name:</b> 2053 0400 511 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 10:51		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-13</b>	<b>Sample Name:</b> 2053 0400 512 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 10:51		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-14</b>	<b>Sample Name:</b> 2053 0400 513 CF 22A (p)						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 10:52		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-15</b>	<b>Sample Name:</b> 2053 0400 514 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 10:52		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-16</b>	<b>Sample Name:</b> 2053 0400 515 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 10:55		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-17</b>	<b>Sample Name:</b> 2053 0400 516 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 10:57		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-18</b>	<b>Sample Name:</b> 2053 0400 517 CF 22A (A2)						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:00		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-19</b>	<b>Sample Name:</b> 2053 0400 518 SF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:00		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-20</b>	<b>Sample Name:</b> 2053 0400 519 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:00		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/18/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2034034

**C Environmental Inspection Services**

**L** Attn: Charles Spear  
**I** 11981 Fargo Rd  
**E** Aurora OR, 97002  
**N** Phone: (503) 680-6398  
**T**

**Project:** WSA  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: Warm Springs Academy 50 Chukar Rd. Warm Springs, OR 977

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2034034-21</b>	<b>Sample Name:</b> 2053 0400 520 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:00		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-22</b>	<b>Sample Name:</b> 2053 0400 521 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:01		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-23</b>	<b>Sample Name:</b> 2053 0400 522 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:03		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-24</b>	<b>Sample Name:</b> 2053 0400 523 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:05		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-25</b>	<b>Sample Name:</b> 2053 0400 524 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:06		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-26</b>	<b>Sample Name:</b> 2053 0400 525 CF 22A (A8)						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:07		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-27</b>	<b>Sample Name:</b> 2053 0400 526 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:10		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-28</b>	<b>Sample Name:</b> 2053 0400 527 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:11		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-29</b>	<b>Sample Name:</b> 2053 0400 528 CF 22A (A18)						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:12		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-30</b>	<b>Sample Name:</b> 2053 0400 529 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:15		<b>Sample Composition:</b> Raw Single				
+Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/18/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2034034

**C** Environmental Inspection Services  
**L** Attn: Charles Spear  
**I** 11981 Fargo Rd  
**E** Aurora OR, 97002  
**N** Phone: (503) 680-6398  
**T**

**Project:** WSA  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: Warm Springs Academy 50 Chukar Rd. Warm Springs, OR 977

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2034034-31</b>	<b>Sample Name:</b> 2053 0400 530 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:15		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-32</b>	<b>Sample Name:</b> 2053 0400 531 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:16		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-33</b>	<b>Sample Name:</b> 2053 0400 532 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:17		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-34</b>	<b>Sample Name:</b> 2053 0400 533 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:20		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-35</b>	<b>Sample Name:</b> 2053 0400 534 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:21		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-36</b>	<b>Sample Name:</b> 2053 0400 535 DW 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:22		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-37</b>	<b>Sample Name:</b> 2053 0400 536 DW 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:25		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-38</b>	<b>Sample Name:</b> 2053 0400 537 BOT 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:26		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-39</b>	<b>Sample Name:</b> 2053 0400 538 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:26		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-40</b>	<b>Sample Name:</b> 2053 0400 539 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:26		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/18/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2034034

**C** Environmental Inspection Services  
**L** Attn: Charles Spear  
**I** 11981 Fargo Rd  
**E** Aurora OR, 97002  
**N** Phone: (503) 680-6398  
**T**

**Project:** WSA  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: Warm Springs Academy 50 Chukar Rd. Warm Springs, OR 977

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2034034-41</b>	<b>Sample Name:</b> 2053 0400 540 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:30		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-42</b>	<b>Sample Name:</b> 2053 0400 541 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:31		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-43</b>	<b>Sample Name:</b> 2053 0400 542 BF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:31		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-44</b>	<b>Sample Name:</b> 2053 0400 543 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:33		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-45</b>	<b>Sample Name:</b> 2053 0400 544 KF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:35		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-46</b>	<b>Sample Name:</b> 2053 0400 545 KF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:36		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-47</b>	<b>Sample Name:</b> 2053 0400 546 KF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:37		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-48</b>	<b>Sample Name:</b> 2053 0400 547 KF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:40		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-49</b>	<b>Sample Name:</b> 2053 0400 548 KF 22A (dish)						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:40		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-50</b>	<b>Sample Name:</b> 2053 0400 549 CF 22A						<b>Matrix:</b> Drinking Water
	<b>Sampled:</b> 1/30/22 11:40		<b>Sample Composition:</b> Raw Single				
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 02/18/2022  
Received: 02/01/2022  
Sampled By: Charles Spear  
Work Order: 2034034

**C** Environmental Inspection Services  
**L** Attn: Charles Spear  
**I** 11981 Fargo Rd  
**E** Aurora OR, 97002  
**N** Phone: (503) 680-6398  
**T**

**Project:** WSA  
Project # : -  
Sample Type : Grab  
PO # : 2021096

Sampling Location: Warm Springs Academy 50 Chukar Rd. Warm Springs, OR 977

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>2034034-51</b>	<b>Sample Name:</b> 2053 0400 550 CF 22A <b>Sampled:</b> 1/30/22 12:00 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-52</b>	<b>Sample Name:</b> 2053 0400 551 CF 22A <b>Sampled:</b> 1/30/22 12:00 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-53</b>	<b>Sample Name:</b> 2053 0400 552 CF 22A <b>Sampled:</b> 1/30/22 12:00 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-54</b>	<b>Sample Name:</b> 2053 0400 553 CF 22A <b>Sampled:</b> 1/30/22 12:00 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-55</b>	<b>Sample Name:</b> 2053 0400 554 CF 22A <b>Sampled:</b> 1/30/22 12:00 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-56</b>	<b>Sample Name:</b> 2053 0400 555 CF 22A <b>Sampled:</b> 1/30/22 12:00 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-57</b>	<b>Sample Name:</b> 2053 0400 556 CF 22A <b>Sampled:</b> 1/30/22 12:00 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-58</b>	<b>Sample Name:</b> 2053 0400 557 BF 22A <b>Sampled:</b> 1/30/22 12:00 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	1	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-59</b>	<b>Sample Name:</b> 2053 0400 558 CF 22A <b>Sampled:</b> 1/30/22 12:00 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10
<b>2034034-60</b>	<b>Sample Name:</b> 2053 0400 559 CF 22A <b>Sampled:</b> 1/30/22 12:20 <b>Sample Composition:</b> Raw Single						<b>Matrix:</b> Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	1	15 ppb	02/16/22 14:10



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 02/18/2022
Received: 02/01/2022
Sampled By: Charles Spear
Work Order: 2034034

C
L
I
E
N
T

Environmental Inspection Services

Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: WSA

Project #: -
Sample Type: Grab
PO #: 2021096

Sampling Location: Warm Springs Academy 50 Chukar Rd. Warm Springs, OR 977

Lab Number

Table with 8 columns: Lab Number, Code, Method, Result, Units, MRL, EPA MCL\*, Analysis Date/ Time. Contains two rows of data for samples 2034034-61 and 2034034-62.

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by:

Handwritten signature of Adriana Gonzalez-Gray

Adriana Gonzalez-Gray
Laboratory Director